

# DISTRICT LEVEL LABORATORY PUBLIC HEALTH ENGINEERING DEPARTMENT

KARIMGANJ DIVISION :: KARIMGANJ  
SETTLEMENT ROAD :: P.O. & DIST. KARIMGANJ (ASSAM)  
PHONE : (03843) 273522

Sl. No.	Pin Point Location of the Water Sample	Date of Collection	Receiving Date	Date of Analysis	Turbidity Unit NJU / JTU	pH Acceptable Range 6.5-8.5	Fe Acceptable limit 0.00-0.30 mg/L	F 1.0-1.5 mg/L	As 1.01-1.05 mg/L	Residual Chlorine 0.2-1 mg/L	Bacteriological 0.2-1 mg/L	Hardness 200-500 mg/L	TDS 500-2000 mg/L	Mn 0.01-0.02 mg/L	Nitrate 0-45 mg/L	Remarks
01	Boring	01-11-19	01-11-19	04-11-19	30 JTU	6.7	0.27 mg/L	0.35 mg/L	NTI	-	Absent	250 mg/L	570 mg/L	-	-	Received water sample is suitable for drinking after filtration.

Sample Received From : *Maharshi Vidya Mandir School,*

*Jitendra Kumar*  
Jitendra Kumar  
Head Assistant  
Karimganj (PHE) Division  
Karimganj

Test Prepared by .....

*[Signature]*



*[Signature]*  
Laboratory In-Charge  
DLL (Karimganj)